

**Young Park Boardwalk
BALDWIN TOWNSHIP PARK IMPROVEMENTS**

ADDENDUM NO. 1

DATE: October 2, 2013

BID OPENING: October 7th, 2013, 7:00 pm

Bids received until 3:30 pm, October 7th, 2013

SUBJECT: Alternate footing

The purpose of this addendum is to provide the Contractor with an acceptable alternate method to construct the foundation for the Boardwalk. The selected Contractor shall inform the Township after being awarded the project which of the two allowable methods for constructing the Boardwalk footings the Contractor would prefer to use. No additional compensation will be awarded for the differing footings.

Section 01020, paragraph B shall read:

B. Materials for footings will be furnished by the owner, including 4x4's, blocks, and sakcrete, or at the contractors request a 16" concrete cookie (circular concrete pad commonly used in pole barn foundations) will be provided.

Section 01020, paragraph F shall read:

F. Pressure Treated 4"x4" wood post centered inside the concrete block and all voids to top of 8" block filled with concrete to form a solid unit. If the contractor chooses to use a concrete cookie for a foundation for the 4"x4" wood posts then the concrete cookie shall be placed such that it lies level in the bottom of the hole and such that the post shall be centered over the top of the cookie.

Jon Bogart, P.E.
Baldwin Town Engineer.